

Homogeneous Area: M08

Material: Air duct

Description: Sonoco Sonoairduct transite ducting

Locations, amount and asbestos content:

Location	Amount	Asbestos Content
Encased in the concrete floor in the 200-hall fan room	~100 linear feet	>10% Chrysotile



Example of transite duct.