

Homogeneous Area: T01

Material: Thermal System Insulation

Description: Mudded Joint Fittings (all sizes)

Locations, amount and asbestos content:

Location	Amount	Asbestos Content
Above the suspended ceilings of rooms and hallways surrounding the South and West sides of the auditorium	~45 joints and elbows	5% Chrysotile

