

Homogeneous Area: T02

Material: Thermal System Insulation

Description: 3" Pipe Runs

Locations, amount and asbestos content:

Location	Amount	Asbestos Content
Above the ceilings in rooms and hallways surrounding the south and west sides of the auditorium	~200 linear feet	10% Amosite

