

Homogeneous Area: T01

Material: Thermal System Insulation

Description: Mudded Joint Fittings (all sizes)

Locations, amount and asbestos content:

Location	Amount	Asbestos Content
Visible in the South-east mechanical area, the closets next to concessions, the upper mechanical room above the gym and in the B-hall custodial closet	~75 visible joints and elbows, undetermined quantity in pipe chases and above ceilings	Up to 5% Chrysotile, up to 7% Amosite, and/or up to 0.5% Crocidolite

