

Homogeneous Area: T02

Material: Thermal System Insulation

Description: Pipe runs (all sizes)

Locations, amount and asbestos content:

Location	Amount	Asbestos Content
Visible in the South-east mechanical area	~200 visible linear feet, undetermined quantity in pipe chases and above ceilings	Up to 5% Chrysotile, up to 7% Amosite, and/or up to 0.5% Crocidolite

